1 Sanitized - Approved For Release TCIA-RDP74-00005R000100060007-1

ARCHIVES & RECORDS CENTER

28 January 1972

MEMORANDUM FOR: Commanding Officer 25X1A6a

ATTN

Engineering Office 25X1A6a

SUBJECT

: Chain Jumping Cogs in Sections 2, 4, 6, 8 8

(Moveable Shelving Project

25X1A1d

 As you know, the chains in Sections 2, 4, 6, 8 8 keep jumping the cogs on the motors when you are trying to move more than one or two rows of shelves. This condition has been in existence ever since the shelves have been loaded. The contractor, Mr. worked on the problem from time to time but doesn't seem to know what is causing the problem.

25X1A5a1

25X1A5a1

- 2. I am concerned that this condition is going to cause major maintenance problems; but more than that, my great concern is that it is causing our boxes to slide off the shelves and scatter the records all over the floor.
- 3. We, the Using Service, cannot live with the above condition; therefore, I do not intend to move any more boxes to free additional new construction space until the problems are resolved to everyone's satisfaction.

4. Also, I just want to call your attention to the fact that som 25X1A5a1 of the rails in the new work done by seems to me to be cutting just as much as the ones were that had been done by and Company. As you know, said that stalled his rails improperly; and they went back and reworked them. I don't know if the rail situation is serious, but I did want you to be aware of the situation.

Chief

25X1A9a

Sanitized - Approved For Release

25X1A5a1